

SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Jim Doyle, Governor Richard J. Leinenkugel, Secretary

April 13, 2010

ECOLAB, INC. REGULATORY AFFAIRS JAMISON KORTAS 370 N. WABASHA ST. ST.PAUL MN 55102-1390

Re: Description: PROPORTIONER
Manufacturer: ECOLAB, INC.
Product Name: PROPORTIONER

Model Number(s): OPTIPRO INSTRUMENT SOILDS ENZYMATIC DETERGENT DISPENSER &

OPTIPRO INSTRUMENT SOILDS NEUTRAL DETERGENT DISPENSER

Product File No: 20100142

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.20 (5) (d) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of April 2015.

This alternate approval is contingent upon compliance with the following stipulation(s):

 The tubing supplied with this product shall be listed for potable water use and have a temperature/ pressure rating of 180 degrees F at 100 psi.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson Plumbing Product Reviewer Phone: 608-266-6742 Fax: 608-267-9566

E-mail: jerry.thompson@wi.gov

SBD-10564-E (N.10/97) File Ref: 10014202.DOC